



April 28, 2004

ZABEL ENVIRONMENTAL TECHNOLOGY
JOHN CHRISTENSEN

PO BOX 1520
CRESTWOOD KY 40014

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ZABEL ENVIRONMENTAL TECHNOLOGY
Product Name: A1800 SERIES ZABEL FILTER
Model Number(s): A1800-4x18, A1800-4x18-VT-B35, A1800-4x22-VT-B35, A1800-4x18-VT-B40, A1800-4x22-VT-B40, and A1801-4x22
Product File No: 20040173

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This approval is contingent upon compliance with the following stipulation(s):

- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The maximum daily wastewater flow, which may discharge through this product, is 800 gallons per day.

This approval supersedes the approval issued on INSERT DATE under product file number 19990001.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 19990001.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov